

SUGGESTED INITIAL FREQUENCY OF INSPECTION AND TESTING OF EQUIPMENT.

	Type of Premises	Type of Equipment	User Checks	Class 1		Class 2	
				Formal Visual Inspection	Combined Inspection and Testing	Formal Visual Inspection	Combined Inspection and Testing
				1	2	3	4
1	Construction sites 110V equipment	Stationary IT Movable Portable Handheld	None None weekly weekly weekly	1 month 1 month 1 month 1 month 1 month	3 months 3 months 3 months 3 months 3 months	1 month 1 month 1 month 1 month 1 month	3 months 3 months 3 months 3 months 3 months
2	Industrial Including Commercial kitchens	Stationary IT Movable Portable Handheld	weekly weekly before use before use before use	None None 1 month 1 month 1 month	12 months 12 months 12 months 6 months 6 months	None None 3 month 3 month 3 month	12 months 12 months 12 months 6 months 6 months
3	Equipment Used by the public	Stationary IT Movable Portable Handheld	None None None None None	monthly monthly weekly weekly weekly	12 months 12 months 6 months 6 months 6 months	3 months 3 months 1 month 1 month 1 month	12 months 12 months 12 months 12 months 12 months
4	Schools	Stationary IT Movable Portable Handheld	weekly weekly weekly weekly before use	None None 4 months 4 months 4 months	12 months 12 months 12 months 12 months 12 months	12 months 12 months 4 months 4 months 4 months	48 months 48 months 48 months 48 months 48 months
5	Hotels	Stationary IT Movable Portable Handheld	None None weekly weekly before use	24 months 24 months 12 months 12 months 6 months	48 months 48 months 24 months 24 months 12 months	24 months 24 months 24 months 24 months 6 months	None None None None None
6	Offices and Shops	Stationary IT Movable Portable Handheld	None None weekly weekly before use	24 months 24 months 12 months 12 months 6 months	48 months 48 months 24 months 24 months 12 months	24 months 24 months 24 months 24 months 6 months	None None None None None

The information on suggested initial frequencies given above is more detailed and specific than HSE guidance, but is not considered to be inconsistent with it.